School Name: Moriah Central School										
Lab ELAP ID#: 11892				Method of Analysis: EPA 200.8						
School Sample ID	Collection Date	Sample Location	Description	Initial / Post Remediation	Lead Result mcg/L (ppb)	Lab Report Date	Action Taken for Outlets Greater than 15 mcg/L (ppb)			
6	3/24/2021	KS6	Ice Machine	Initial	0.0186	4/8/2021	Replaced Filter, Valves, Lines			
12	3/24/2021	Dark Room	Sink	Initial	0.044	4/8/2021	Shut Down / Removed from Service			
21	3/24/2021	RM 166 S2	Sink	Initial	0.0349	4/8/2021	Shut Down / Removed from Service			
23	3/24/2021	RM 136	Sink	Initial	0.0866	4/8/2021	Shut Down / Removed from Service			
25	3/24/2021	HS Nurse S2	Sink	Initial	0.0262	4/8/2021	Shut Down / Removed from Service			
32	3/24/2021	RM 101 S1	Science Sink	Initial	0.0339	4/8/2021	Labeled "DO NOT DRINK"			
38	3/24/2021	Elem Nurse S1	Sink	Initial	0.0199	4/8/2021	Replaced Faucet, Filter, Valves, Lines			
39	3/24/2021	Elem Office S1	Sink	Initial	0.035	4/8/2021	Cut Back Line, Replaced			
72	3/24/2021	RM 216 S1	Sink	Initial	0.017	4/8/2021	Replaced Faucet, Valves, Lines			